

DECLARATION OF CONFORMITY ***No CE-0051-16-03***

On the base of supervision carried out for all activities affecting the quality of our products in accordance with Company's Quality Assurance System based on ISO 9001 and on the base of carried out the following tests,

We:

TECHNOKABEL SA
Nasielska 55, 04-343 Warsaw, Poland

declare with a full responsibility that products/type:

**Low-frequency telecommunication station cables with PVC insulation
and PVC sheath (max. operating voltage 150V)**

Types:

YTTY; YTDY; YTDYekw; YnTDY

this statement are applicable to comply with the following normative documents:

Technical Documentation: **DT 298/08/24**

Polish Standards: **PN-91/T-90200; PN-EN 60332-1-2, PN-EN 60332-2-2**

***Cables do not spread the flame in accordance with the requirements of standards:
PN-EN 60332-1-2 or PN-EN 60332-2-2.***

conformity with the rules of Directives:

2014/35/EU

European Parliament and Council Directive of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits.

PEŁNOMOCNIK Prezesa Zarządu
ds. Systemów Zarządzania
[Signature]
mgr inż. Marcin Kwiatkowski

Warsaw, 19.05.2026