

DECLARATION OF CONFORMITY

No CE-0055-19-03

On the base of supervision carried out for all activities affecting the quality of our products in accordance with Company's Quality Assurance System based on ISO 9001 and on the base of carried out the following tests,

We: **TECHNOKABEL SA**
Nasielska 55, 04-343 Warsaw, Poland

declare with a full responsibility that products/type:

**TECHNOFLAME - Cables for fire installations with insulation and sheaths
made of halogen free material
(operating voltage 150 V; peak value voltage max. 300 V)**

Types:

HTKSH; HTKSHekw

this statement are applicable to comply with the following normative documents:

Technical Documentations: **CNBOP-PIB-KOT-2019/2024/0111-3701 1st edition; WT-TK-4**
Polish/European Standards: **PN-EN 60228, PN-EN 61034-2, PN-EN 60754-1, PN-EN 60754-2,
PN-EN 60332-1-2, PN-EN 60332-3-22 (cat. A), PN-EN 60332-3-24 (cat. C)**
International Standards: **IEC 61034-2, IEC 60754-2**

**Cables do not spread the flame in accordance with the requirements of standards:
PN-EN 60332-1-2; IEC 60332-1-2; PN-EN 60332-3-22; IEC 60332-3-22 (cat. A),
PN-EN 60332-3-24; IEC 60332-3-24 (cat. C).**

conformity with the rules of Directive:

2014/35/EU **European Parliament and Council Directive of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits.**

Warsaw, 01.12.2025

PELNOUĆNIK Procesu Zarządu
ds. Systemów Zarządzania

mgr inż. Marcin Kwiatkowski