

DECLARATION OF CONFORMITY No 59a/1/17

On the base of supervision carried out for all activities affecting the quality of our products in accordance with Company's Quality Assurance System based on ISO 9001 and on the base of carried out the following tests,

We: **TECHNOKABEL S.A.**
Nasielska 55, 04-343 Warsaw, Poland

declare with a full responsibility that products/type:

TECHNOKONTROL - control cable for intrinsically safe circuits and hazardous areas with PVC insulation and oil resistant PVC sheath, (operating voltage 300/500V)

Types:

**IB-YSLCY; IB-YSLCYv; IB-YSLYCY;
IB-YSLCY-P; IB-YSLYCY-P; IB-YSLYCY-T**

this statement are applicable to comply with the following normative documents:

Technical Documentation: **DT 28/01/04**
Polish Standards: **PN-EN 60228, PN-EN 60811-404, PN-EN 60079-14**
European Standards: **EN 60228; EN 60811-404**

**Cables do not spread the flame in accordance with the requirements of standards:
PN-EN 60332-1-2; IEC 60332-1-2.**

conformity with the rules of Directives:

2014/35/EU European Parliament and Council Directive of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits.

Warsaw, 04.04.2024

PEŁNOMOCNIK Prezesa Zarządu
ds. Systemów Zarządzania
M. Kwiatkowski
mgr inż. Marusz Kwiatkowski

(Signature, name and post of the person
authorised to draw up the declaration)