

## **DECLARATION OF CONFORMITY**

### **No CE-0150-17-02**

*On the base of supervision carried out for all activities affecting the quality of our products in accordance with Company's Quality Assurance System based on ISO 9001 and on the base of carried out the following tests,*

*We:* **TECHNOKABEL SA**  
**Nasielska 55, 04-343 Warsaw, Poland**

*declare with a full responsibility that products/type:*

**TECHNOKONTROL - control cable for intrinsically safe circuits and hazardous areas with PVC insulation and oil resistant PVC sheath, for operating voltage 300/500 V**

*Types:*

**IB-YSLCEY ; IB-YSL(St)Y PIMF; IB-YSL(St)Yv PIMF;  
IB-YSLCY PIMF; IB-YSLCEY PIMF**


*this statement are applicable to comply with the following normative documents:*

Technical Documentation: **DT 28/01/04**  
Polish Standards: **PN-EN 60228, PN-EN 60332-1-2, PN-EN 60811-404,  
PN-EN 60079-14**  
European Standard: **EN 60228; EN 60332-1-2; EN 60811-404; EN 60079-14**

**Cables do not spread the flame in accordance with the requirements of standards:  
PN-EN 60332-1-2; IEC 60332-1-2.**

*conformity with the rules of Directives:*

**2014/35/EU** European Parliament and Council Directive of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits.

PEŁNOMOCNIK Prezesa Zarządu  
ds. Systemów Zarządzania  
  
mgr inż. Mariusz Kwiatkowski

Warsaw, 06.03.2026