

DECLARATION OF CONFORMITY

No CE-0184-16-02

On the base of supervision carried out for all activities affecting the quality of our products in accordance with Company's Quality Assurance System based on ISO 9001 and on the base of carried out the following tests,

We: **TECHNOKABEL SA**
Nasielska 55, 04-343 Warsaw, Poland

declare with a full responsibility that products/type:

.....
MINING CONTROL CABLES
for operating voltage up to 0,6/1 kV

Types:

YnHKGSY 300/500 V; YnHKGSY 0,6/1 kV; YnHKGSYkono 0,6/1 kV

.....
this statement are applicable to comply with the following normative documents:

Technical Documentation: WT-TK-25
Polish Standards: PN-EN 60228; PN-EN 60332-1-2; PN-EN 60332-3-24
International Standards: IEC 60332-3-24

Cables do not spread the flame in accordance with the requirements of standards: PN-EN 60332-1-2; IEC 60332-1-2; PN-EN 60332-3-24; IEC 60332-3-24 (cat. C)

conformity with the rules of Directives:

2014/35/EU **European Parliament and Council Directive of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits.**

Warsaw, 18.12.2025

PELNOMOCNIK Zarządu
ds. Systemów Zarządzania

mgr inż. Marcin Kwiatkowski