

## DECLARATION OF CONFORMITY No 247a/1/18

On the base of supervision carried out for all activities affecting the quality of our products in accordance with Company's Quality Assurance System based on ISO 9001 and on the base of carried out the following tests,

We: **TECHNOKABEL SA**  
**Nasielska 55, 04-343 Warsaw, Poland**

declare with a full responsibility that products/type:

**Fire resistant halogen free installation cables  
for operating voltage 300/500 V**

Types:

**HDGs(-W) FE180 PH120/E30-E90,  
HDGsekw FE180 PH120/E30-E90,  
HLGs FE180 PH120/E30-E90,  
HLGsekw FE180 PH120/E30-E90,**

this statement are applicable to comply with the following normative documents:

Polish Standard:	<b>CNBOP-PIB-KOT-2018/2023/0054-3701 wydanie 1</b>
European Standards:	<b>PN-EN 60228; PN-EN 50200, PN-EN 61034-2, PN-EN 60754-1/-2</b>
German Standard:	<b>DIN 4102.12</b>
International Standards:	<b>IEC 60331-21; IEC 60754-2</b>
Technical Documentation:	<b>WT-TK-46</b>

Cables do not spread the flame in accordance with the requirements of standards:  
**PN-EN 60332-1-2; IEC 60332-1-2; PN-EN 60332-3-22; IEC 60332-3-22**

conformity with the rules of Directives:

**2014/35/EU** European Parliament and Council Directive of 26 February 2014 on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits.

Warsaw, 13 November 2023

PEŁNOMOCNIK Prezesa Zarządu  
ds. Systemów Zarządzania

mgr inż. *Mariusz Kwiatkowski*

(Signature, name and post of the person  
authorised to draw up the declaration)